

TECHNICAL SPECIFICATIONS

Model	Voltage	Power
/R000E000x	230 V ~, 50/60 Hz	3 VA, 25 mA ~ max
/R000A000x	115 V ~, 50/60 Hz	3 VA, 50 mA ~ max
/R000F000x	115 to 230 V ~, 50/60 Hz	6 VA, 50 mA ~ max
/R000G000x	12 to 24 V ~, 50/60 Hz; 12 to 30 Vdc	3 VA, 300 mA ~ /ImAde max
/R000H000x	12 V ~, 50/60 Hz; 12 to 18 Vdc	Use only SEU power supply

Insulation guaranteed by the power supply

Insulation	Reference	Reinforced
to very low voltage parts	reinforced	6 mm clearance, 8 mm creepage
to relay outputs	basic	3 mm clearance, 4 mm creepage
to very low voltage parts	externally guaranteed by safety transformer (SEU power supply)	3 mm clearance, 4 mm creepage
to relay outputs	reinforced	6 mm clearance, 8 mm creepage
to relay outputs	3750 V insulation	3750 V insulation

Inputs

Model	Probe	Max. current
S1 (probe 1)	NTC (R000A000x) or NTC e PTC (R000T000x)	10 mA
S2 (probe 2)	NTC (R000A000x) or NTC e PTC (R000T000x)	10 mA
D11	free contact, contact resistance < 10 Ω, closing current 6 mA	6 mA
S3 (probe 3)	NTC (R000A000x) or NTC e PTC (R000T000x)	10 mA
D12	free contact, contact resistance < 10 Ω, closing current 6 mA	6 mA
S4 (probe 4)	NTC (R000A000x) or NTC e PTC (R000T000x)	10 mA

Probe type

Model	Temperature range	Measurement error
S1d, CAREL NTC	1 to 120 °C in the -50/150 °C range	± 0.5 °C in the -50/150 °C range
NTC high temperature	50 to 120 °C in the -40/150 °C range	± 0.5 °C in the -40/150 °C range
PTC std. CAREL (specific model)	90 to 125 °C in the -20/115 °C range	± 0.5 °C in the -20/115 °C range
PTC std. CAREL (specific model)	12 to 125 °C in the -50/150 °C range	± 0.5 °C in the -50/150 °C range

Relay outputs

Model	Relay	Operating cycles	250 V ~	Operating cycles
/R000A000x	R2 (*)	5 (1)A	5 A resistive IFLA 12 LRA C300	30000
/R000A000x	R3 (*)	5 (1)A	5 A resistive IFLA 12 LRA C300	30000
/R000A000x	R1, R2	8 (4)A N.O.	8 A resistive 2 FLA 12 LRA C300	30000
/R000A000x	R2, R3	2 (2)A N.O./C	2 A resistive 2 FLA 12 LRA C300	30000
/R000A000x	R1	12 (2)A N.O./C	12 A resistive 5 FLA 30 LRA C300	30000

SSR outputs

Model	Max. output voltage	Output resistance	Max. output current
/R000A000x	12 Vdc	600 Ω	20 mA

Signals on the display

The blinking status indicates a request for activation that cannot be implemented until the end of the corresponding delay times.

Icon	Function	ON	OFF	blink	Startup
COMPRESS	compressor ON	comp. ON	comp. OFF	compressor request	
DEFROST	defrost in progress	defrost ON	defrost OFF	defrost request	
AUX	auxiliary output AUX active	AUX ON	AUX OFF	anti-sweat heater function active	
ALARM	delayed external alarm (before the expiry of the time RT)	no alarm present	alarm present	alarms in normal operation (eg. high/low temp.) or alarm from ext. digital input immediate or delayed	
CLOCK	at least one timed defrost has been set	no timed defrost is present	clock alarm	clock alarm	On if RealTime Clock pre-
LIGHT	auxiliary output LIGHT ACTIVE	LIGHT ON	LIGHT NOT ACTIVE	anti-sweat heater function active	
SERVICE		no malfunction	malfunction (eg. EEPROM error or probe fault)		
HACCP	HACCP function	HACCP function enabled	HACCP function not enabled		
CONTINUOUS CYCLE	Enabled	not enabled	request		

Tab. 1

Buttons on the keypad

Button	Normal operation	Special operation	Start-up: if pressed for more than 5 s	Automatic address assignment: if pressed for 1 s
↑	pressed for more than 1 s: sets the menu for setting type "T" (frequency) parameters	pressed for more than 5 s together with UP/AUX button, enables/disables the alarm relay	pressing together with other buttons	pressing together with other buttons
↓	pressed for more than 1 s: silences the audible alarm (buzzer) and disables the alarm relay	pressed for more than 5 s together with DOWN/DEF button, enables/disables the continuous cycle operation	pressing together with other buttons	pressing together with other buttons
↻	pressed for more than 1 s: enables/disables the auxiliary output	pressed for more than 5 s together with SET button, starts the procedure for printing the reports (function available, with management to be implemented)	pressing together with other buttons	pressing together with other buttons
↺	pressed for more than 1 s: displays and/or sets the set point	pressed for more than 5 s together with PRG/MUTE button, accesses the menu for setting the type "C" parameters "T" (configuration) or downloading the parameters	pressing together with other buttons	pressing together with other buttons
↻	pressed for more than 1 s: displays and/or sets the set point	pressed for more than 5 s together with DOWN/DEF button, displays a submenu with the HACCP alarm parameters (HA, HAN, HE, HFN)	pressing together with other buttons	pressing together with other buttons

Tab. 2

Summary of operating parameters (UOM = Unit of measure; Def. = Default value).

Symbol	Code	Parameter	Models	UOM	Type	Min	Max	Def.
Pw		Password	MSYF	-	C	0	200	22
/2		Measurement stability	MSYF	-	C	1	15	4
/3		Probe display response	MSYF	-	C	0	15	0
/4		Virtual probe	MSYF	-	C	0	100	0
/5		Select "C" or "F" 0: "C" 1: "F"	MSYF	flag	C	0	1	0
/6		Display decimal point with tenths of a degree without tenths of a degree	MSYF	flag	C	0	1	0
/7		Display on internal terminal 1: virtual probe 2: probe 1 3: probe 2 4: probe 3 5: probe 4 6: probe 5 7: set point	MSYF	-	C	1	7	1
/E		Display on external terminal remote terminal not present 1: virtual probe 2: probe 1 3: probe 2 4: probe 3 5: probe 4 6: probe 5	MSYF	-	C	0	6	0
/P		Select type of probe 0: NTC standard with range -50/190 °C 1: NTC enhanced with range -40/150 °C 2: PTC standard with range -50/150 °C	MSYF	-	C	0	2	0
/A2		Configuration of probe 2 (S2) 0: Probe absent 1: Product probe (display only) 2: Defrost probe 3: Condenser probe 4: Antifreeze probe	YF	-	C	0	4	2
/A3		Configuration of probe 3 (S3, D11) As for /A2	MSYF	-	C	0	4	0
/A4		Configuration of probe 4 (S4, D12) As for /A2	MSYF	-	C	0	4	0
/c1		Calibration of probe 1	MSYF	°C/°F	C	-20	20	0.0
/c2		Calibration of probe 2	MSYF	°C/°F	C	-20	20	0.0
/c3		Calibration of probe 3	MSYF	°C/°F	C	-20	20	0.0
/c4		Calibration of probe 4	MSYF	°C/°F	C	-20	20	0.0
S1		Temperature set point	MSYF	°C/°F	F	17	12	0.0
/d1		Control delay	SYF	s	F	0.1	20	2.0
/m		Dead band	SYF	°C/°F	C	0.0	60	4.0
/r		Reverse differential for control with dead band	SYF	°C/°F	C	0.1	20	2.0
/1		Minimum set point allowed	MSYF	°C/°F	C	-50	12	-50
/2		Maximum set point allowed	MSYF	°C/°F	C	11	200	60
/3		Operating mode 0: Direct (cooling) with defrost control 1: Direct (cooling) 2: Reverse-cycle (heating)	SYF	flag	C	0	2	0
/r4		Automatic night-time set point variation	MSYF	°C/°F	C	-20	20	3.0
/r5		Enable temperature monitoring 0: Disabled 1: Enabled	MSYF	flag	C	0	1	0
/r		Temperature monitoring interval	MSYF	hours	F	0	999	1
/M		Maximum temperature read	MSYF	°C/°F	F	-	-	-
/r		Minimum temperature read	MSYF	°C/°F	F	-	-	-
c0		Comp., fan and AUX delay on start-up in dead band	SYF	min	C	0	15	0
c1		Minimum time between successive starts	SYF	min	C	0	15	0
c2		Minimum compressor OFF time	SYF	min	C	0	15	0
c3		Minimum compressor ON time	SYF	min	C	0	15	0
c4		Duty setting	SYF	min	C	0	100	0
cc		Continuous cycle duration	SYF	hours	C	0	15	0
c6		Alarm bypass after continuous cycle	SYF	hours	C	0	250	2
c7		Maximum pump down time	SYF	s	C	0	900	0
c8		Comp. start delay after open PD valve (factory default: 0, not visible from display)	SYF	C	0	65	0	0
c9		Enable outstart function in PD	SYF	flag	C	0	1	0
c10		Select Pump down by time or pressure Pump down by time Pump down by pressure	SYF	flag	C	0	1	0
c11		Second compressor delay	SYF	s	C	0	250	4

Symbol	Code	Parameter	Models	UOM	Type	Min	Max	Def.
d0		Type of defrost 0: Electric heater defrost by temperature 1: Hot gas defrost by temperature 2: Electric heater defrost by time 3: Hot gas defrost by time 4: Electric heater defrost thermostat by time	SYF	flag	C	0	4	0
d1		Interval between defrosts	SYF	hours	F	0	250	8
d1		End defrost temperature, evaporator	SYF	°C/°F	F	-50	200	4.0
d2		End defrost temperature, aux. evap.	SYF	°C/°F	F	-50	200	4.0
dP1		Maximum defrost duration, evaporator	SYF	min	F	1	250	30
dP2		Maximum defrost duration, aux. evap.	SYF	min	F	1	250	30
d3		Defrost start delay	SYF	min	C	0	250	0
d4		Enable defrost on start-up 0: No defrost is performed when the instrument is switched on 1: A defrost is performed when the instrument is switched on	SYF	flag	C	0	1	0
d5		Defrost delay on start-up	SYF	min	C	0	250	0
d6		Display on hold during defrost 0: Alternating display of dEF and probe value 1: Display of the last temp. shown 2: Display of dEF steady	SYF	-	C	0	2	1
d7		Drooping time after defrost	SYF	min	F	0	15	2
d8		Alarm bypass after defrost	SYF	hours	F	0	250	1
d9		Alarm bypass after door open	SYF	min	C	0	250	0
d9		Defrost priority over compressor protectors 0: The protection times c1, c2 and c3 are observed 1: The protection times c1, c2 and c3 are not observed	SYF	flag	C	0	1	0
d1		Display of defrost probe 1	MSYF	°C/°F	F	-	-	-
d2		Display of defrost probe 2	MSYF	°C/°F	F	-	-	-
dC		Time base for defrost 0: dl in hours, dP1 and dP2 in minutes 1: dl in minutes, dP1 and dP2 in seconds	SYF	flag	C	0	1	0
d10		Compressor running time	SYF	hours	C	0	250	0
d11		Running time temperature threshold	SYF	°C/°F	C	-20	20	1.0
d12		Advanced defrost	SYF	-	C	0	3	0
dn		Nominal defrost duration	SYF	-	C	1	100	65
dH		Proportional factor, variation in dl	SYF	-	C	0	100	50

Symbol	Code	Parameter	Models	UOM	Type	Min	Max	Def.
td1		Defrost time band 1	SYF	days </td <td>C</td> <td>-</td> <td>-</td> <td>-</td>	C	-	-	-
d_		Day		days	C	0	11	0
h_		Hour		hours	C	0	23	0
m_		Minute		min.	C	0	59	0
td2		Defrost time band 2	SYF	-	C	-	-	-
td3		Defrost time band 3	SYF	-	C	-	-	-
td4		Defrost time band 4	SYF	-	C	-	-	-
td5		Defrost time band 5	SYF	-	C	-	-	-
td6		Defrost time band 6	SYF	-	C	-	-	-
td7		Defrost time band 7	SYF	-	C	-	-	-
td8		Defrost time band 8	SYF	-	C	-	-	-
tdn		Light/aux on time band, set point variance	SYF	-	C	-	-	-
d_		Day		days	C	0	11	0
h_		Hour		hours	C	0	23	0
m_		Minute		min.	C	0	59	0
tof		Light/aux off time band, set point variance	SYF	-	C	-	-	-
d_		Day		days	C	0	11	0
h_		Hour		hours	C	0	23	0
m_		Minute		min.	C	0	59	0
tc		RTC date/time setting	MSYF	-	C	-	-	-
y_		Year		years	C	0	99	0
m_		Month		months	C	1	12	1
d_		Day of the month		days	C	1	31	1
u_		Day of the week		days	C	1	7	6
h_		Hour		hours	C	0	23	0
m_		Minute		min.	C	0	59	0

Important: for the set times to become immediately operational, the instrument must be turned off and on again, otherwise the times will become operational when the instrument is next started, during the setting of the internal timers.

"The appliance (or the product) must be disposed of separately in accordance with the local waste disposal legislation in force"

Symbol	Code	Parameter	Models	UOM	Type	Min	Max	Def.
A0		Alarm and fan differential	MSYF	°C/°F	C	0.1	20	2.0
A1		Type of threshold 'AL' and 'AH' 0: AL and AH are relative thresholds to the set point 1: AL and AH are absolute thresholds	MSYF	flag	C	0	1	0
AL		Low temperature alarm threshold	MSYF	°C/°F	F	-50	200	0.0
AH		High temperature alarm threshold	MSYF	°C/°F	F	-50	200	0.0
AD		Low and high temperature signal delay	MSYF	min	F	0	250	120
A4		Digital input 1 configuration (DI1) 0: Input not active 1: Immediate external alarm 2: Delayed external alarm 3: If model M, probe selection 4: Other models enable defrost 5: Start defrost 6: Remote on/off 7: Curtain switch 8: Low pressure switch 9: Door switch with fan stop only 10: Direct/reverse 11: Light sensor 12: Activation of the AUX output 13: Door switch with compressor and fans off and light not managed 14: Door switch with fans only off and light not managed	SYF	M	C	0	14	3
A5		Digital input 2 configuration (DI2) As for A4	MSYF	-	C	0	14	0
A6		Stop compressor from external alarm	SYF	min	C	0	100	0
A7		External alarm detection delay	SYF	min	C	0	250	0
A8		Enable alarms 'Ed1' and 'Ed2' 0: Alarm signals Ed1 and Ed2 enabled 1: Alarm signals Ed1 and Ed2 disabled	SYF	flag	C	0	1	0
Ado		Light management mode with door switch	MSYF	flag	C	0	1	0
Ac		High condenser temperature alarm	SYF	°C/°F	C	0.0	200	70.0
AEd		High condenser temperature alarm differential	SYF	°C/°F	C	0.1	20	10
AcD		High condenser temperature alarm delay	SYF	min	C	0		